

Declaration of Conformity (DoC)
Declaration of Conformity No HW/4/2017

1. Manufacturer:
MERCOR S.A. Zakład Produkcyjny [Production Site] w Cieplewie, ul. Kwarцова 3A, 83-031 Łęgowo
2. Product name:
Fire dampers type mcr FID S, mcr FID C, mcr FID PRO, mcr WIP, mcr WIP PRO, mcr ZIPP.
3. Statistical classification of the building product:
26.30.50.0
4. Intended use and scope of application of the product:
Fire dampers type mcr FID S, mcr FID C, mcr FID PRO, mcr WIP, mcr WIP PRO, mcr ZIPP, are designed for use in general and fire ventilation systems, where those systems pass through construction partitions. During a fire, the dampers preserve the fire resistance of the construction partition where ventilation and air conditioning ducts are routed through. Furthermore, they prevent spreading of fire, smoke and burning fumes to the remaining part of building which is not on fire.
5. Declared technical features of building product:
 - Closed blade air leakage according to PN-EN 1751 – minimum class 2
 - Casing air leakage mounted in construction partition according to PN-EN 1751 – class C*Note: Declared air leakage is valid only when damper is installed accordingly to OMM provided by manufacturer.*

I declare under my sole responsibility, that the products to which this declaration refers comply with the specification showed in paragraph no 5

Gdańsk, 2017-05-31

Date and place of issue

CZŁONEK ZARZĄDU
DYREKTOR PIONU

Tomasz Kamiński

Full name of authorised person